



BV LCIE
CHINA
Number

N° 1666AS07NCR21456

ATTESTATION of conformity with European Directives

<i>Product:</i>	Electromechanical contactor
<i>Reference</i>	CJX2-25 ; CJX2-32; CJX2-40; CJX2-50; CJX2-63; CJX2-80; CJX2-95
<i>Issued to</i>	CNC Electric Group Co., Ltd
<i>Address</i>	Changcheng High-tech Industrial Zone, North Baixiang, Yueqing, Zhejiang, 325 603
<i>Manufacturer</i>	CNC Electric Group Co., Ltd
	Ue=380V
	Ie=25A; 32A; 40A; 50A; 63A; 80A; 95A
<i>Technical characteristics</i>	50/60Hz
	Utilization category: AC-3
	Number of pole: 3P

The submitted sample of the above equipment has been tested for **CE** marking according to following European Directive and following standards:

Low Voltage Directive 2014/35/EU

Standards	Report number	Report date
EN60947-4-1:2010 + A1:2012	NCR-16JY1939ITSP	25/07/2016

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive.

This verification does not imply assessment of the production of the product.
The CE marking may be affixed if all relevant and effective European Directives with CE are applicable.

Shanghai (P.R. China),), July 27th, 2016.

CE

This document shall not be reproduced, except in full, without the written approval of BV LCIE China.
Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA

必维欧亚电气技术咨询服务(上海)有限公司

Version 3/2016.02.19

Building 4, No. 818, Xin Zuan Road,
CaoHeJing Songjiang High-Tech Park,
Shanghai P.R.C (201612)

Tel: +86 21 6195 7000
Fax: +86 21 6195 7001

Email: contact@cn.bureauveritas.com